Fire Emergency Plan	
Management company	Litmus (Nottingham)
Managing agents	Residential Management Group
Effective date of plan	February 2023
In the event of Fire	Action
How people will be warned if	Independent ceiling mounted alarms are fitted within each flat.
there is a fire.	
	Additionally, automatic fire alarms are fitted in all flats which are
	interlinked to the main building alarm and if one alarm sounds it will put
	the system into full alarm sounding in all flats.
If a fire breaks out in your home	Verbally raise the alarm by shouting "FIRE, FIRE, FIRE "and repeat this call
	throughout your escape until you leave the building.
	Warn all persons within your flat and leave together.
	Where possible turn off any cooking equipment.
	Where possible close windows and doors, but especially the front door.
	Do not use the lift.
	Leave the building by the nearest available escape stair.
	Do not attempt to put out the fire.
	Do not put yourself at risk.
	Move to a safe place away from the building.
If you see or hear of a fire in	Although the building is constructed with a high degree of fire protection
another part of the building	the evacuation plan for this building requires all residents to proceed to a
	safe place if they hear any <b>vocal cry</b> or <b>alarm</b> .
	You must also leave <b>immediately</b> if smoke or heat affects your home, or if
	you are told to do so by the fire service. If in doubt, get out.
Hearing the alarm (relevant	Evacuate the building immediately by using the nearest staircase but do
persons who may be elsewhere	not use the lift.
in the building)	If you have visitors or contractors with you, instruct them to follow you.
	Leave the building by the nearest available exit.
How will the emergency services	The person finding the fire should dial <b>999</b> or <b>112</b> .
be notified and who is	When the operator answers, give your telephone number and ask for FIRE.
responsible	When the fire service replies give the address where the fire is:
	195 Huntingdon Street, Nottingham, NG13NT
	Do not end the call until the fire service has repeated the address correctly.
Arrangements for the safe	Details of any individuals with special needs should be held with relevant
evacuation of people identified	documentation in the Secure Information Box (SIB).
as being especially at risk	
Plans to deal with persons once	All evacuated personnel should remain at a safe distance away from the
they have left the premises	block. No individual should re-enter the building for any reason until they
they have left the premises	have been instructed to do so.
Assembly Point	Residents should ensure they move to a safe place at least 100m away at
	the front of the block.